

Technical Report No. 61

Steam In Place

2013



PDA Technical Report No. 61: Steam in Place Task Force Members

Authors

Kevin Trupp (Task Force Chair), Retired
Dave Adams, Baxter Healthcare Corporation
Keith E. Bader, Hyde Engineering and Consulting
Michael N. Blackton, ImClone Systems, Inc.
Keith A. Bowen, Centocor, Inc.
Garth Corkill, Pall Life Sciences
Tim P. Cirbo, Eli Lilly and Company
Jose A. Goin, Ph.D., Genentech

Leesa D. McBurnie, Meissner Filtration Products, Inc.
Lance L. Morien, Centocor-Global Biologics Supply Chain
Michael P. Mulcare, Biogen Idec
Anton Ponomarenko, Bayer Healthcare
Tony Van Hoose, Sanofi Pasteur
Edward K. White, Baxter Healthcare Corporation
Randy Wilkins, Millipore Corporation

Contributors

Martin Kern, Hermes Pharma
Victor G. Maqueda, Sr. (no company affiliation)

Keith Shuttleworth, Keith Shuttleworth & Associates
Nigel Wood, GlaxoSmithKline

The Steam in Place Task Force would like to dedicate this technical report in memory of Lance Morien.

The content and views expressed in this Technical Report are the result of a consensus achieved by the authorizing Task Force and are not necessarily views of the organizations they represent.

Steam In Place

Technical Report No. 61

ISBN: 978-0-939459-53-7

© 2013 Parenteral Drug Association, Inc.

All rights reserved.



Table of Contents

1.0 INTRODUCTION	1	7.0 ONGOING PROCESS CONTROL	37
1.1 Scope.....	1	7.1 Use of Risk Management for Ongoing Process Control.....	37
2.0 GLOSSARY OF TERMS	3	7.2 Routine Monitoring	37
3.0 STEAM IN PLACE SCIENCE AND TECHNOLOGY 7		7.2.1 Operational Parameters.....	37
3.1 SIP Applications.....	7	7.2.2 Filter Testing	38
3.2 Mechanisms of Lethality.....	8	7.3 Change Control/Revalidation.....	38
4.0 SYSTEM DESIGN	11	7.4 Periodic Requalification/Revalidation	38
4.1 Planning for Design of SIP Cycle	11	7.5 Preventative Maintenance Strategy.....	39
4.2 Equipment Design Considerations	11	7.6 Calibration Strategy	39
4.3 SIP System Control and Monitoring.....	16	8.0 APPENDICES	40
4.3.1 Automation	16	8.1 Appendix A: Risk Assessment of Steam in Place Processes.....	40
4.3.2 Controlling the SIP Cycle.....	17	8.1.1 Introduction.....	40
4.3.3 SIP for Portable Vessels	17	8.2 Risk Assessment Tools	40
4.3.4 Semi-Manual and Manual SIP Operations	18	8.2.1 Hazard Analysis and Critical Control Point (HACCP).....	40
5.0 CYCLE DEVELOPMENT CONSIDERATIONS	19	8.2.2 Failure Mode and Effects Analysis (FMEA).....	41
5.1 Use of Risk Management during Development	20	8.3 Example of HACCP for a New SIP Process	42
5.1.1 Risk Assessment	20	8.4 Example of FMEA for a Steam in Place Process	45
5.1.2 Risk Mitigation.....	21	8.4.1 Risk analysis	45
5.1.3 Cycle Development Data.....	21	8.4.2 Risk Evaluation.....	45
5.1.4 Testing	21	8.4.3 Risk Assessment	45
5.2 Cycle Parameter Determination	21	8.4.4 Risk Reduction/Post-mitigation RPR	46
5.3 Filter Cycle Development Considerations	24	8.5 Appendix B: Lyophilizer SIP Design and Cycle Considerations	47
5.3.1 Wet Filters	24	8.5.1 Lyophilizer Chamber, Shelves, and Ram...	47
5.3.2 Filter Integrity Tests	24	8.5.2 Lyophilizer Condenser	47
5.4 Temperature Mapping.....	25	8.5.3 Heating and Cooling System.....	48
6.0 PERFORMANCE QUALIFICATION	26	8.5.4 Chamber Vacuum Pumps.....	48
6.1 Use of Risk Management during Qualification	26	8.5.5 Vent and Compressed Gas Filters	48
6.1.1 System/Equipment Qualification	26	8.5.6 Clean-in-Place (CIP) Spray Devices.....	48
6.1.2 Cycle Qualification	27	8.5.7 Chamber Isolation Valve.....	48
6.2 Physical Qualification.....	27	8.5.8 Post-sterilization Leak Test.....	49
6.2.1 Sanitization vs. Sterilization	27	8.5.9 Cycle Considerations for Lyophilizers.....	49
6.2.2 Temperature Mapping.....	28	8.5.10 Pre-SIP Phases for Lyophilizers	49
6.3 Biological Qualification.....	29	8.5.11 Typical SIP Phases for Lyophilizers	50
6.3.1 Microbial Challenge	30	8.5.12 Validation Considerations for Steam in Place.....	50
6.3.2 Use and Placement of Biological Indicators.....	31	9.0 REFERENCES	52
6.4 Qualification Acceptance Criteria.....	34		
6.5 Validation Approaches	35		
6.5.1 Family Validation.....	36		
6.5.2 Matrix Validation.....	36		

FIGURES AND TABLES INDEX

Figure 1.1-1	Steam in Place Life Cycle	2	Table 5.2-1	Example of Typical SIP Cycle Operational Parameters	22
Table 3.1-1	Includes some example applications of SIP processes, cycle development considerations, and potential validation approaches	7	Figure 5.3.2-1	Example of In Situ Filter Integrity Test ...	25
Figure 3.2-1	Microbial Survivor Curve	9	Figure 6.2.2-1	Example of Probe Orientation	28
Table 3.2-1	Example Lethality Rates (F_0 per Minute) at Various Process Temperatures	9	Figure 6.2.2-2	TC 1 vs. TC 2 Temperature Profile.....	29
Figure 3.2-2	Optimal Heat Transfer Curve.....	10	Table 6.3.2-1	Types of Biological Indicators	32
Figure 3.2-3	Effect of Trapped Air on Steam Temperature	10	Figure 6.3.2-1	Example of BI Placement.....	33
Figure 4.2-1	Example of Steam Distribution and Process Tank Layout.....	12	Figure 6.3.2-2	Example of Pipe with BIs and TC Connection Gland	34
Table 4.2-1	Comparison of Pros and Cons for When to Perform the Pre-Use Filter Integrity Test .	14	Figure 6.3.2-3	Example of pipe with BIs with Ported Gasket	34
Table 4.2-2	Temperature Reduction Caused by Air..	15	Figure 8.2-1	Critical Control Point Decision Tree....	41
Table 4.2-3	An example of considerations for steam trap selection.....	16	Table 8.2.2-1	Risk Ranking Assignment Chart	42
Table 4.3-1	Examples of Levels of Automation	17	Figure 8.3-1	Manufacturing Process Flow Diagram Depicting Stages of HACCP Analysis....	43
Table 5.0-1	Typical Steps and Phases of an SIP Cycle with Relevant Objectives	19	Table 8.3-1	HACCP Analysis Table	44
Figure 5.0-1	Example of SIP Cycle Phases	20	Table 8.4.2-1	Risk Prioritization Ranking Chart.....	45
			Figure 8.4.3-1	Example of Bioreactor Vessel System	46
			Table 8.4.4-1	Assessment of Manufacturing SIP Process	47
			Figure 8.5-1	Simplified Schematic of a Lyophilizer and Condenser	48

1.0 Introduction

PDA Technical Report No. 1, *Validation of Moist Heat Sterilization Processes: Cycle Design, Development, Qualification and Ongoing Control*, updated in 2007, focuses on the microbiology and engineering concepts of moist heat sterilization and the general approach to sterilization science in batch sterilizers (autoclaves) (1). This technical report is intended to complement PDA Technical Report No. 1 and will focus on steam in place (SIP) processes.

The primary objective of the task force responsible for this technical report was to develop a scientific technical report on SIP processes that provides recommendations for use by industry and regulators. References to appropriate and up-to-date scientific publications, international regulatory documents, journal articles, technical papers, and books are used to provide more detail and supportive data can be found.

Steam in Place was chosen as the title because this document focuses on the various applications of steam for in situ sterilization for “sterile” applications and for in situ sanitization and other bioburden control applications widely used for systems that do not claim to be “sterilized” via steam. We also differentiate “steam in place” from the more generic term “sterilize in place” used to describe in situ sterilization using various types of gaseous or liquid sterilizing agents including steam (1).

The task force was composed of European, North American, and South American industry professionals to ensure the methods, terminology, and practices of SIP reflect sound science and can be applied globally. This technical report was disseminated for public review and comment prior to publication, to provide the widest possible review and ensure its suitability as a guide to industry.

SIP is often a pivotal step of aseptic processing for sterile product manufacture, and as such, may benefit from the application of risk management methodologies. The characterization, evaluation, and assessment of risk are useful to direct overall efforts for cycle development and subsequent validation. After development of a risk assessment, more resources can be focused on mitigating risk for systems, equipment, or processes that have the highest potential for product contamination. The management of risk may be employed throughout the lifecycle of SIP equipment and processes to efficiently focus and allocate resources commensurate with the probability of impacting final product purity and safety. Descriptions of the specific steps and tools for risk management are available from a variety of sources (2,3).

1.1 Scope

The scope of this technical report is limited to discussion of SIP processes that provide moist heat sterilization and/or sanitization of equipment and systems supporting the manufacture of medicinal products. The principles discussed in this report may also be applied to those systems where portable equipment is steamed at a fixed station (steam out of place).

Application of the concepts presented in this technical report to laboratories or other non-CGMP applications, including hospitals, is not intended.

The following concepts are out of scope:

- Clean-in-Place (except where related to SIP)
- In situ media sterilization
- Product Sterilization
- Design and qualification of utilities